

## DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)



**FLEXI®**  
**COAT**

**1121-CPR-JA5014**

**1. Unique identification code of product-type:**

FLEXCS

**2. Type, Batch or serial number as required pursuant to Article 11(4):**

See ETA 14/0048 : See batch number displayed on product.

**3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:**

Fire Stopping and Sealing Products for Linear Joint & Gap Seal, See ETA 14/0048

Linear Joint & Gap Seals	Horizontal & Vertical Linear Joints in Rigid floor constructions	The field of application has to comply with the content of ETA 14/0048
--------------------------	--	--

**4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):**

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

**5. Authorized representative: N/A**

**6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1**

**7. Harmonized standard: N/A**

**8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:**

Warrington Certification Limited issued European Technical Approval - ETA 14/0048 on the basis of ETAG 026 part 1 General June 2013 fire protection products & ETAG 026 part 3 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5014

**9. Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 14/0048 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 14/0048 Clause 3.3
Water Permeability	Tested in accordance with EN 1027
Dangerous Substances	See ETA 14/0048 Clause 3.5
Airbourne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See ETA 14/0048 Clause 3.9 - $R_w (C;Ctr) = 30 (G;-2) \text{ dB}$
Service & Durability	Z <sup>1</sup> (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
Movement Capability	According to ETAG 026-3, clause Annex 13.5.1 & 13.5.2, See ETA 14/0048
Other	Not applicable/No performance determined

**10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for and on behalf of the manufacturer by:

*P. Kieser*

25/02/2014

P.Kieser - Managing Director

*C. Dicken*

25/02/2014

C.Dicken - Technical Manager



Astroflame Ltd  
Unit 8, The I O Centre  
Stephenson Road  
Segensworth, Fareham  
Hampshire, PO15 5RU

Tel: +44 (0) 1329 844500  
Fax: +44 (0) 1329 844600  
Email: sales@astroflame.com  
Website: www.astroflame.com

