

Trade Name: ASTRO CT SLEEVE

Intumescent Cable Tray Sleeve

COSHH Data

Installation Data

Product Images

Installation Video

2 Hour fire rating to BS 476

Suitable for use through a wide range of fire partition walls and floors

Offers excellent acoustic insulation

Maintains the thermal insulation of the wall or floor

Cost effective: easily cut to minimize wastage, no mastic or foam is required, reducing on site time

Simple to install without special tools or skills

Sleeve can be easily fitted only requiring access from one side

Suitable for retro fitting

Allows thermal movement



Description

The ASTROflame range of ASTRO CT Cable Tray Sleeves are intended for use where a cable tray passes through a fire rated wall or floor. The sleeve reinstates the fire rating of the wall or floor which would otherwise be lost.

In the event of a fire, the advanced ASTRO CT Cable Tray Sleeve will expand with the heat, closing off any holes or gaps to the fire for at least 2 hours. The Fire Cable Tray Sleeves are available to fit all cable tray sizes

Availability

Astroflame Cable Tray Fire Sleeves are currently available in the following nominal sizes:

Item	Cable Tray Width [mm]	Sleeve Width [mm]	Length [mm]	Product Code
CT Cable Sleeve	50	100	150	AFCT100
CT Cable Sleeve	75	125	150	AFCT125
CT Cable Sleeve	100	150	150	AFCT150
CT Cable Sleeve	150	200	150	AFCT200
CT Cable Sleeve	225	275	150	AFCT275

CT Cable Sleeve	300	350	150	AFCT350
CT Cable Sleeve	450	500	150	AFCT500

Packed - Individually

To Order & Specify

Please quote - Quantity / Trade name / Product Ref / Size

Typical wording:- 6no Astro Cable Tray Sleeve / AFCTS125 / 125MM

Fire Tests

Cable Tray Fire Sleeves have undergone and passed testing in line with BS476 Part 22:1987 at Chiltern International Fire

Health and Safety

Refer to COSHH sheet

As part of our policy of ongoing improvements, we reserve the right to modify, alter or change product specifications without giving notice. Product illustrations are representations only. All information contained in this document is provided for guidance only, and as ASTROFLAME FIRESEALS LTD has no control over the installation methods of the products, or of the prevailing site conditions, no warranties expressed or implied are intended to be given as to the actual performance of the products mentioned or referred to, and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given of products mentioned or referred to herein.

The above information to the best of our knowledge is true and accurate and based upon current test data and is supplied for your guidance only. Customers should satisfy themselves to the suitability of the product in its intended use and no guarantee is given or implied since the conditions of actual use are beyond our control. ASTROflame (Fireseals) Ltd, disclaim any liability for loss, damage or other expense arising from the use of information, data or products mentioned or referred to and reserve the right to change any details or specifications without notice.

Astroflame (Fire Seals) Ltd. Intumescent House
Unit 8, The IO Centre, Stephenson Road, Segensworth
FAREHAM, ENGLAND PO15 5RU

tel 0800 023 2482
(01329 844500)

fax 0800 023 2483
(01329 844600)

intl
tel +44 1329 844500

fax +44 1329 844600

email sales@astroflame.com

[Homepage.](#)