

Intumescent Fire Trunking Sleeve

Trade Name: ASTRO FT SLEEVE



2 Hour fire rating to BS 476

Suitable for use through a wide range of fire partition walls and floors

**Offers excellent acoustic insulation
Maintains the thermal insulation of the pipe through the penetration**

Cost effective: one sleeve can replace two collars, easily cut to size to minimize wastage, no mastic is required

Sleeve can be easily fitted only requiring access from one side

Can also be fitted flush to the wall offering a clean wall solution

Sleeves tested for Metallic and polymeric pipe through plasterboard wall and solid floor and polymeric pipes through a mineral fibre batt.

Description

The Astroflame range of Astro FT Fire Trunking Sleeves are intended for use where plastic trunking passes through a fire rated wall. The sleeve reinstates the fire rating of the wall which would otherwise be lost.

In the event of a fire, the Astro FT Trunk Sleeve expands with the heat, crushing the trunking and closing off the hole to the fire for at least 2 hours.

The FT Trunk Sleeves are available to fit common sizes of plastic trunking and are suitable for retro fitting with access only required from one side. They are suitable for use with plastic trunking or can be used with cabling passed directly through the sleeve. 25mm thick wall

Availability

Astroflame Fire Trunking Sleeves are currently available to fit the following nominal plastic trunking sizes

Item	Width [mm]	Height [mm]	Length [mm]	Product Ref
Firetrunk Sleeve	50	50	150	AFFTS50
Firetrunk Sleeve	100	100	150	AFFTS100

Packed - Individually

To Order & Specify

Please quote - Quantity / Trade name / Product Ref / Size

Typical wording:- 6no Astro Fire Trunking Sleeve / AFFTS50 / 50MM

Fire Tests

Astroflame Fire Trunking Sleeves have undergone and passed testing inline with BS476 Part 22:1987 at Chiltern Internatioanl Fire

Health And Safety

Refer to COSHH sheet

As part of our policy of ongoing improvements, we reserve the right to modify, alter or change product specifications without giving notice. Product illustrations are representations only. All information contained in this document is provided for guidance only, and as ASTROFLAME FIRESEALS LTD has no control over the installation methods of the products, or of the prevailing site conditions, no warranties expressed or implied are intended to be given as to the actual performance of the products mentioned or referred to, and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given of products mentioned or referred to herein.

The above information to the best of our knowledge is true and accurate and based upon current test data and is supplied for your guidance only. Customers should satisfy themselves to the suitability of the product in its intended use and no guarantee is given or implied since the conditions of actual use are beyond our control. ASTROflame (Fireseals) Ltd, disclaim any liability for loss, damage or other expense arising from the use of information, data or products mentioned or referred to and reserve the right to change any details or specifications without notice.

Astroflame (Fire Seals) Ltd. Intumescent House
Unit 8, The IO Centre, Stephenson Road, Segensworth
FAREHAM, ENGLAND PO15 5RU

tel 0800 023 2482
(01329 844500)

fax 0800 023 2483
(01329 844600)

intl
tel +44 1329 844500

fax +44 1329 844600

email