

Intumescent Glazing Tape

Trade Name: ASTROTAPE



Tested to BS476: Part 22: 1987

Available in Brown, White or Black

½ hour Fire Rating

Easy & Clean Application

A pliable re-shaped strip that bonds well to Wood & Glass

NHBC Type Approval.

A flexible self adhesive polymer based extruded intumescent material suitable for sealing wired or fire resistant glazing into wooden fire doors and fire resistant partitions.

On exposure to heat from a fire Astroflame Intumescent tape swells, thus prohibiting smoke and flame from passing through the aperture between wood and glass, providing resistance in excess of 1/2 hour.

Supplied in roll form it offers the user a high performance, non load bearing tape for accurate placement, with no waste and requiring no specialist applications.

Availability

CODE	COLOUR	SIZE
AFIT12B	BROWN	12mm x 3mm x 15mtr
AFIT12W	WHITE	12mm x 3mm x 15mtr
AFIT12BLK	BLACK	12mm x 3mm x 15mtr

Colours

Available in:- Brown, White or Black

Packing

12 rolls per carton

To Order & Specify

Please quote - Quantity/Tradename/Product Ref./Colour/ etc,
Typical wording:- 24/ ASTROTAPE / AFT12B / BROWN

Fire Tests Or Assessment

Warrington Fire Research: Global Assessment
C100767 Trada/Chiltern: RF40523
NHBC Type Approval.

Health And Safety

The product does not present any known health hazards during or after installation. Normal good industrial and personal hygiene practices should be observed.

Areas For Use-Glazing

When glazing internally, using wired or fire resistant glass, the entire glazing system should be able to withstand the effects of the fire for as long as the glass, therefore Astroflame Intumescent tape should be used in this area.

As part of our policy of ongoing improvements, we reserve the right to modify, alter or change product specifications without giving notice. Product illustrations are representations only. All information contained in this document is provided for guidance only, and as ASTROFLAME FIRESEALS LTD has no control over the installation methods of the products, or of the prevailing site conditions, no warranties expressed or implied are intended to be given as to the actual performance of the products mentioned or referred to, and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given of products mentioned or referred to herein.

The above information to the best of our knowledge is true and accurate and based upon current test data and is supplied for your guidance only. Customers should satisfy themselves to the suitability of the product in its intended use and no guarantee is given or implied since the conditions of actual use are beyond our control. ASTROflame (Fireseals) Ltd, disclaim any liability for loss, damage or other expense arising from the use of information, data or products mentioned or referred to and reserve the right to change any details or specifications without notice.

Astroflame (Fire Seals) Ltd. Intumescent House
Unit 8, The IO Centre, Stephenson Road, Segensworth
FAREHAM, ENGLAND PO15 5RU

tel 0800 023 2482
(01329 844500)

fax 0800 023 2483
(01329 844600)

intl
tel +44 1329 844500

fax +44 1329 844600

email