

DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)



ASTRO INTU®

MASTIC

2812-CPR-JA5015

1. Unique identification code of product-type:

INTUM

2. Type, Batch or serial number as required pursuant to Article 11(4):

See ETA 14/0050 : See batch number displayed on product.

3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:

Fire Stopping and Sealing Products for Linear Joint & Gap Seal, See ETA 14/0050

Linear Joint & Gap Seals	Horizontal & Vertical Linear Joints in Flexible wall constructions	The field of application has to comply with the content of ETA 14/0050
Linear Joint & Gap Seals	Horizontal & Vertical Linear Joints in Rigid wall constructions & rigid floor constructions & steel constructions & wood constructions	The field of application has to comply with the content of ETA 14/0050

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

5. Authorized representative: N/A

6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

7. Harmonized standard: N/A

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Element issued European technical approval - ETA 14/0050 on the basis of EAD 3501412-00-1106 Fire Stopping and Fire Sealing Products & issued certificate of conformity 2812-CPR-JA5015

9. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F According to EN13501-1
Reaction to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 14/0050 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 14/0050 Clause 3.3
Dangerous Substances	See ETA 14/0050 Clause 3.5
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See ETA 14/0050 Clause 3.9 - Rw (C;Ctr) = 63 (G;-2) dB & Rw (C;Ctr) 38dB
Service & Durability	Type: X intended for use in conditions exposed to weathering in accordance with EOTA technical documents TR024
Movement Capability	According to ISO 11600 : ISO 11600 - F - 7.5p.
Other	Not applicable/No performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 17/09/2020

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 17/09/2020