

Construction Product Regulation (EU) 305 2011

ASTRO®**PFP FR PIPE WRAP****0843-CPR-0560**

1. Unique identification code of the product-type:

Astro PFP FR Pipe Wrap

2. Type, batch or serial no. or any other element allowing identification of the construction product as required pursuant to article 11(4):

See packaging for batch number**2.1.** Astro PFP FR Pipe Wrap is supplied in 50mm and 75mm widths of 1.8mm thick strips.**2.2.** In accordance with article 11(4) all products are supplied with product code, date of manufacture and with all manufacturing processes traceable through the Factory Production controls (FPC) held in the product technical files.**3.** Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer, and in accordance with the applicable European Assessment Document (Hereinafter EAD): EAD 350454-00-1104 (penetration seals).**3.1** The intended use of system Astro PFP FR Pipe Wrap is to reinstate fire resistance performance of flexible wall constructions, rigid wall construction and rigid floor construction where they are penetrated by various plastic and metal pipe services with and without combustible insulation when used in combination with Astro PFP FR EX mortar and Astro PFP FR Board.**3.2** The specific elements of construction that the system Astro PFP FR Pipe Wrap may be used to provide a penetration seals in Astro PFP FR EX mortar and Astro PFP FR Boards, are as follows:

- Flexible walls: The wall must have a minimum thickness of 100 mm and comprise steel studs lined on both faces with minimum 2 layers of 12.5 mm thick boards.
- Rigid walls: The wall must have a minimum thickness of 100mm (unless stated otherwise in ETA 20/0198) and comprise concrete, aerated concrete or masonry, with a minimum density of 650 kg/m³.
- Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated concrete or concrete with a minimum density of 650 kg/m³.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

*** minimum wall thickness is dependent on approvals specified in ETA 20/0198 Annex A.****3.3** The system Astro PFP FR Pipe Wrap may be used to provide a penetration seal with specific, uninsulated metal pipes, and plastic pipes specific supporting construction and substrates (for details see ETA 20/0198 Annex A). Pipes shall be supported at maximum 270 mm away from both faces of the wall constructions and from the upper face of floor constructions.**3.4** The provisions made in the European Technical Assessment (ETA 20/0198) are based on an assumed working life of the Astro PFP FR Pipe Wrap of 10 years, however provided that the conditions laid down in the manufacturers' instructions and datasheet for the packaging/transport/storage/installation/use/repair are met the assumed working life of Astro PFP FR Pipe Wrap for internal conditions without exposed to UV or moisture is 30 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.**3.5** Type X: Intended for Internal and external use in conditions exposed to weathering. When used in combination with Astro PFP FR Board or Astro PFP FR EX Mortar the intended uses is limited to internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to article 11(5):

Astroflame (Fire Seals) Ltd.
Intumescent House
Unit 8, The IO Centre,
Stephenson Road, Segensworth
Fareham, England PO15 5RU

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of consistency of performance of the construction product as set out in annex V:

AVCP-System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard

Not applicable

DECLARATION OF PERFORMANCE

Construction Product Regulation (EU) 305 2011



ASTRO®

PFP FR PIPE WRAP

0843-CPR-0560

8. In case of the declaration of performance concerning a construction product for which a European Technical assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines set out within EAD EAD 350454-00-1104 (penetration seals).
ETA 20/0198 prepared by UL International (UK) Ltd notified body 0843 issued on issued on 20/03/2020.
EC Certificate of conformity 0843-CPR-0560.

9. Declared performance:

Essential characteristics	Performance	Test Standard
Product –type: Wrap	Intended use: Penetration Seal	
Reaction to Fire	Class E	EN 13501-1
Resistance to Fire	ETA 20/0198 Annex A	EN 13501-2
Air permeability (material property)	Not relevant	EN 1026:2000
Water permeability (material property)	Not relevant	ETAG 026-2 Annex C
Release of dangerous substances	As the manufacture we declare that there is no release of dangerous substances during the installation or use of this product. See safety data sheets.	
Mechanical Resistance and stability	Not relevant	EOTA TR 001:2003
Resistance to impact/movement	Not relevant	EOTA TR 001:2003
Airborne sound insulation	Not relevant	EN 10140-2
Impact sound insulation	Not relevant	EN 10140-3
Thermal properties	Not relevant	EN 12664, EN12667, or EN12939
Water vapour permeability	Not relevant	EN ISO 12572, EN 12086
Durability and serviceability	X	ISO 8339:2005, ISO 9046:2004 & ISO 7389

10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 03/04/2020

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 03/04/2020