

ASTRO®**PFP FR PUTTY SEAL****0843-CPR-0488**

1. Unique identification code of the product-type:

Astro PFP FR Putty Seal

2. Type, batch or serial no. or any other element allowing identification of the construction product as required pursuant to article 11(4):

See packaging for batch number

2.1 Astro PFP FR Putty Seal, is supplied in Ø 15mm cord for service penetrations, 4mm pads for electrical and tap water sockets.

2.2 In accordance with article 11(4) all products are supplied with product code, date of manufacture and all manufacturing processes traceable through Polyseam's Factory Production controls (FPC) held in the product technical files.

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer, and in accordance with the applicable European Assessment Document (Hereinafter EAD): ETAG 026-2 (penetration seals).

3.1 Astro PFP FR Putty Seal is a flexible pad or cord used to reinstate the fire resistance performance of wall constructions where they have been provided with apertures for the penetration of pipes into electrical and tap water socket boxes, on both sides of the wall, and single electrical cables up to 21mm.

3.2 The specific elements of construction that the system Astro PFP FR Putty Seal may be used to provide a penetration seal in, are as follows:

Flexible walls: The wall must have a minimum thickness of 100 mm and comprise steel studs lined on both faces with minimum 2 layers of 12.5 mm thick.

Rigid walls: The wall must have a minimum thickness of 100 mm (and comprise concrete, aerated concrete or masonry, with a minimum density of 650 kg/m³).

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

3.3 The provisions made in this European Technical Assessment are based on an assumed working life of the Astro PFP FR Putty Seal of 50 years, provided that the conditions laid down in the product datasheet for the packaging/transport/ storage/installation/use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the manufacturer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3.4 Type Z2: Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to article 11(5):

Astroflame (Fire Seals) Ltd.
Intumescent House
Unit 8, The IO Centre,
Stephenson Road, Segensworth
Fareham, England PO15 5RU

5. Where applicable, name and contact address of the authorized representative whose mandate cover the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of consistency of performance of the construction product as set out in annex V:

AVCP-System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Not applicable

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines set out within ETAG 026 part 2 (penetration seals).

ETA 19/0006 prepared by UL International (UK) Ltd notified body 0843.

EC Certificate of conformity 0843-CPR-0488.

DECLARATION OF PERFORMANCE

Construction Product Regulation (EU) 305 2011



ASTRO®

PFM FR PUTTY SEAL

0843-CPR-0488

9. Declared performance:

Product –type: Putty	Intended use: Penetration Seal	
Essential characteristics	Performance	Test Standard
Reaction to Fire	NPD	EN 13501-1
Resistance to Fire	ETA 19/0006 Annex A	EN 13501-2
Air permeability (material property)	NPD	EN 1026:2000
Water permeability	NPD	ETAG 026-2, Annex C
Release of dangerous substances	As the manufacture we declare that there is no release of dangerous substances during the installation or use of this product. See safety data sheets.	
Mechanical Resistance and stability	NPD	EOTA TR 001:2003
Resistance to impact/movement	NPD	EOTA TR 001:2003
Adhesion properties	NPD	EOTA TR 001:2003
Airborne sound insulation	NPD*	EN 10140-2
Impact sound insulation	NPD	EN 10140-3
Thermal properties	NPD	EN 12664, EN 12667 or EN 12939
Water vapor permeability	NPD	EN ISO 12572, EN 12086
Durability and serviceability	Z ₂	ISO 8339:2005, ISO 9046:2004 & ISO 7389

*Astro PFM FR Putty Pads have been tested according to BS EN ISO 140-3:1995. Result: 67 (-2;-7)Rw (C;Ctr) (dB). See data sheet for details

10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 7/2/2019

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 7/2/2019