



UKCA CERTIFICATE

APPROVED BODY NUMBER 0843

UK CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 0843-CPR-1319

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: Astroflame Fireseals Ltd

Address: Unit 8, The IO Centre, Stephenson Road, Segensworth, Fareham

Hampshire, PO15 5RU

Product Description: Firestop – Penetration Seals and Linear Joint Seals

Model Reference: ASTRO PFP FR Acrylic

Places of production: A/003

UK Assessment 0843-UKTA-23/0028 & 0843-UKTA-23/0027 and EAD 350454-00-1104 &

Document(s) & UKTA: EAD 350141-00-1106

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in 0843-UKTA-23/0028 & 0843-UKTA-23/0027, under system 1/1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the UK Assessment Document/UK Technical Assessment, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.

Date of 1st issue: 28th November 2023

Issue: 1
Date of re-issue: N/A

Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:

Name: Chris Johnson

Signed on behalf of the Head of

Approved Body





UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1319

Detailed information sheet

Model Reference: ASTRO PFP FR Acrylic

Type: Firestop – Sealant used as a penetration seal and linear joint seal

Description: A sealant used to form a penetration seal around metallic pipes, plastic

pipes, composite pipes, combustible cable conduits and electrical cables to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of

services. The sealant can also be used to form linear gap seals where gaps are present in wall and floor constructions and linear joint seals where wall and floor constructions abut. The ASTRO PFP FR Acrylic is supplied in liquid form contained within 310 & 380 ml cartridges and 600 ml foil packs. The sealant is gunned into the aperture in the separating element/elements and around the service or services, to a specified depth utilising a backing

material.

Key Performance parameters: See 0843-UKTA-23/0028 & 0843-UKTA-23/0027

Technical documentation:

UL Report: To be used in accordance with the supplier's installation instructions.

Limitations on the acceptance or use of the product(s):

Installation instructions

To be used in accordance with the supplier's installation instructions.

Terms and Conditions:

- 1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
- 2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
- 3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
- 4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
- 5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1st issue: 28th November 2023

Issue: 1
Date of re-issue: N/A

Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:

Name: Chris Johnson

Signed on behalf of the Head of

Approved Body