



4705



Solutions

## UKCA CERTIFICATE

## APPROVED BODY NUMBER 0843

UK CERTIFICATE OF CONSTANCY OF PERFORMANCE  
CERTIFICATE No. 0843-CPR-1318

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: Astroflame Fireseals Ltd

Address: Unit 8, The IO Centre, Stephenson Road, Segensworth, Fareham  
Hampshire, PO15 5RU

Product Description: Firestop – Penetration Seals

Model Reference: ASTRO PFP Pipe Closer


Places of production: A/003

UK Assessment Document(s) & UKTA: 0843-UKTA-23/0026 and EAD 350454-00-1104

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in 0843-UKTA-23/0026, under system 1/1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the UK Assessment Document/UK Technical Assessment, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.

Date of 1<sup>st</sup> issue: **28<sup>th</sup> November 2023**  
Issue: **1**  
Date of re-issue: **N/A**  
Issued by UL International (UK) Ltd., Approved Body 0843.

  
Signed:  
Name: Chris Johnson  
Signed on behalf of the Head of  
Approved Body



4705



# UKCA CERTIFICATE

**Solutions**

## Schedule for certificate No. 0843-CPR-1318

### Detailed information sheet

Model Reference: ASTRO PFP Pipe Closer  
Type: Firestop – Pipe closure device used as a penetration seal  
Description: A pipe closure device used to form penetration seals where combustible pipes, cables and metal pipes with insulation penetrate walls and floors. ASTRO PFP Pipe Closer is supplied with intumescent liner complete within metal steel shell, to be clamped around the service and screw fixed back to the supporting element. The ASTRO PFP Pipe Closer may be supplied with powder coated steel or stainless steel shell.

Key Performance parameters: See 0843-UKTA-23/0026

### Technical documentation:

UL Report: To be used in accordance with the supplier's installation instructions.

### Limitations on the acceptance or use of the product(s):


Installation instructions To be used in accordance with the supplier's installation instructions.

### Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1<sup>st</sup> issue: **28<sup>th</sup> November 2023**  
Issue: **1**  
Date of re-issue: **N/A**  
Issued by UL International (UK) Ltd., Approved Body 0843.

  
Signed:  
Name: Chris Johnson  
Signed on behalf of the Head of  
Approved Body

Page 2 of 2