

# UL-EU CERTIFICATE

**Certificate No.** UL-EU-00837-A1

**Page** 1/7

**Date of Issue** 2015-09-09

**Certificate Holder** ASTROFLAME FIRESEALS LIMITED  
UNIT 8 THE IO CENTRE  
SEGENSWORTH  
FAREHAM  
PO15 5RU  
United Kindgom

**Manufacturer** A/008

**Certified Product Type** Fire Stop – Sealant

**Product Trade Name** Astro HPE Sealant

**Trademark** N/A

**Rating/Classification** See Appendix

**Harmonised Technical Specifications** ETAG 026-2 / EN 13501-2

**Supporting Documentation** ETA 14/0096, EC – CERTIFICATE OF CONSTANCY OF PERFORMANCE - 1121 – CPR – JA5024

**Additional information** Additional test evidence is held on file

**Expiry date** 2025-07-01

---

**Director, Global Market Access Operations**

Helena Y. Wolf

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



[www.ul.com](http://www.ul.com)

# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-00837-A1  
Page 2/7  
Date of Issue 2015-09-09

This certificate relates to the use of Astro HPE Sealant for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 7 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes (EI 240).

The product is certificated on the basis of:

- i) ETA 14/0096
- ii) EC – CERTIFICATE OF CONSTANCY OF PERFORMANCE 1121 – CPR – JA5024
- iii) Inspection and surveillance of factory production control by UL
- iii) Fire resistance test data in accordance with 1366-3: 2009
- iv) Classification in accordance with EN 13501-2
- v) Durability and Servicability as defined in ETAG 026-2

The durability class of Astro HPE Sealant is Z<sub>1</sub> - intended for use at internal conditions with high humidity, excluding temperatures below 0°C



# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-00837-A1  
 Page 3/7  
 Date of Issue 2015-09-09

Product-type: Sealant (reactive)		Intended use: Penetration Seal
Basic requirement for construction work	Basic Requirement	Basic requirement for construction work
<b>BWR 1 Mechanical resistance and stability</b>		
-	None	-
<b>BWR 2 Safety in case of fire</b>		
EN 13501-1	Reaction to fire	Class F
EN 13501-2	Resistance to fire	See page 5
<b>BWR 3 Hygiene, health and environment</b>		
EN 1026:2000	Air permeability (material property)	See page 4
ETAG 026-3, Annex C	Water permeability (material property)	No performance determined
Declaration of manufacturer	Release of dangerous substances	Declaration of manufacturer
<b>BWR 4 Safety in use</b>		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined
EOTA TR 001:2003	Resistance to impact/movement	No performance determined
EOTA TR 001:2003 ISO 11600	Adhesion	No performance determined
<b>BWR 5 Protection against noise</b>		
EN 10140-2/ EN ISO 717-1	Airborne sound insulation	R <sub>w</sub> (C;C <sub>tr</sub> )= 52(-1;-6)
EN 10140-3/ EN ISO 717-2	Impact sound insulation	No performance determined
<b>BWR 6 Energy economy and heat retention</b>		
EN 12664, EN 12667 or EN 12939	Thermal properties	No performance determined
EN ISO 12572 EN 12086	Water vapour permeability	No performance determined
<b>General aspects relating to fitness for use</b>		
ISO 8339: 2005, ISO 9046: 2004 & ISO 7389: 2003	Durability and serviceability	Z <sub>1</sub>
<b>BWR 7 Sustainable use of natural resources</b>		
-	-	No performance determined





# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-00837-A1  
Page 4/7  
Date of Issue 2015-09-09

## Astro HPE Sealant: Air Permeability according to BS EN 1314-1

Pressure (Pa)	Results under positive chamber pressure		Results under negative chamber pressure	
	Leakage (m <sup>3</sup> /h)	Leakage (m <sup>3</sup> /m <sup>2</sup> /h)	Leakage (m <sup>3</sup> /h)	Leakage (m <sup>3</sup> /m <sup>2</sup> /h)
50	0.2	5.6	0.3	8.3
100	0.4	11.1	0.6	16.7
150	0.7	19.4	0.9	25.0
200	1.0	27.8	1.2	33.3
250	1.1	30.6	1.6	44.4
300	1.2	33.3	1.9	52.8
450	2.2	61.1	2.7	75.0
600	2.4	66.7	3.4	94.4



# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-00837-A1  
 Page 5/7  
 Date of Issue 2015-09-09

Substrate	Minimum Substrate Thickness (mm)	Seal annulus (mm)	Seal Position	Minimum Seal Depth (mm)	Backing Material	Service/insulation	Fire Resistance (mins.)			
							E	EI		
Drywall/ Masonry/ Concrete wall	120	10	Both sides	25	None	40 mm diameter PVC Pipe with 1.9-3mm wall thickness	120	120		
		16			Rock fibre mineral wool 30 mm deep and 80 kg/m <sup>3</sup>	125 mm diameter PVC Pipe with 4.8-7.4mm wall thickness				
		300 x 100 (seal size)			None	63 mm diameter HDPE Pipe with 7.2mm wall thickness			120	120
		12.5				Electrical cables up to 21 mm diameter				
		20				90 mm diameter HDPE Pipe with 9.2mm wall thickness				
		15			90 mm diameter ABS Pipe with 6mm wall thickness	60 mm diameter Copper or Steel pipe with 0.8-14.2 mm wall thickness and insulated with 32 mm Armaflex AF*			120	90
	100	20		25	None	40 mm diameter PVC Pipe with 1.9mm wall thickness	120	120		
						125 mm diameter PVC Pipe with 9.2mm wall thickness				
						40 mm diameter ABS Pipe with 1.9mm wall thickness				
						40 mm diameter HDPP Pipe with 2mm wall thickness				
						40 mm diameter Copper or Steel pipe with 1.5-14.2 mm wall thickness and insulated with 32 mm Armaflex AF**			120	30
						40-159 mm diameter Copper or Steel pipe with 2.0-14.2 mm wall thickness and insulated with 32 mm Armaflex AF**				
						159 mm diameter Copper or Steel pipe with 2.0-14.2 mm wall thickness and insulated with 30 mm Pipelane SGR glass wool tube (80kg/m <sup>3</sup> ) **				

\* Continuous through seal and full length of the pipe (CS)

\*\* Continuous through seal and extending minimum 650 mm from both faces of the seal (LS)



# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-00837-A1

Page 6/7

Date of Issue 2015-09-09

Substrate	Minimum Substrate Thickness (mm)	Seal annulus (mm)	Seal Position	Minimum Seal Depth (mm)	Backing Material	Service/insulation	Fire Resistance (mins.)	
							E	EI
Concrete floor	150	50 x 50 – 200 x 200 (seal size)	Upper face	25	Rock fibre mineral wool 100 mm deep and 45 kg/m <sup>3</sup>	Electrical cables up to 21 mm diameter	180	120
						Electrical cables 22 to 80 mm diameter	120	120
						Non-sheathed electrical cables up to 24 mm diameter	180	15
						Telecomms cables up to 21 mm diameter (bundles up to 100 mm diameter)	180	20
		41-159 mm diameter Copper or Steel pipe with 2.5-14.2 mm wall thickness and insulated with 16-32 mm Armaflex AF*				120	120	
		50-110 mm diameter PP Pipe with 2.1 to 10.7 mm wall thickness				30	30	
		50 mm diameter PP Pipe with 2.1mm wall thickness				240	240	
		110 mm diameter PP Pipe with 10.7 mm wall thickness				120	120	
		40-125 mm diameter PE Pipe with 4.1 to 11.4 mm wall thickness				60	60	
		40 mm diameter PE Pipe with 4.1 mm wall thickness				240	240	
		125 mm diameter PE Pipe with 11.4 mm wall thickness				90	90	
		40-114 mm diameter PVC Pipe with 2.0 to 8.1 mm wall thickness				90	30	
		40 mm diameter PVC Pipe with 2.0 mm wall thickness				240	240	
114 mm diameter PVC Pipe with 8.1 mm wall thickness	120	120						

\* Continuous through seal and full length of the pipe (CS)





# Appendix UL-EU Certificate

<b>Certification Mark</b>	<b>UL-EU mark</b>
<b>Certificate No.</b>	UL-EU-00837-A1
<b>Page</b>	7/7
<b>Date of Issue</b>	2015-09-09

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Certificate Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

## PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at [www.ul.com](http://www.ul.com).

